

**54-8a-10.5 Installation and location of sewer lateral cleanouts -- Records.**

- (1)
  - (a) An operator or person installing or replacing a sewer lateral cleanout beginning August 1, 2009 shall install or replace the sewer lateral cleanout in a manner so that the lateral can be located, including:
    - (i) house sheets; or
    - (ii) electronic markers.
  - (b) An operator or person installing a sewer lateral cleanout shall notify the sewer operator of the sewer lateral cleanout location for record keeping purposes.
- (2) Beginning on August 1, 2009, a sewer operator shall maintain records identifying where all new, replaced, or contractor-identified sewer lateral cleanouts are located within the sewer operator's jurisdiction.
- (3)
  - (a) A sewer operator shall provide to an excavator information in the sewer operator's possession pertaining to a sewer lateral cleanout location within the sewer operator's jurisdiction.
  - (b) The sewer operator shall provide the information within 48 hours of the excavator's request.

Enacted by Chapter 209, 2009 General Session